



# AGA CERTIFIED PRODUCT

Certificate Holder:	<b>UNI-GERÄTE E. MANGELMANN ELEKTROTECHNISCHE FABRIK GmbH</b>
ABN/ACN No. (if applicable):	<b>N/A</b>
Manufacturer:	<b>UNI-Geräte E. Mangelmann Elektrotechnische Fabrik GmbH</b>
Agent (if applicable):	<b>N/A</b>
Type of Component:	<b>Automatic Shut-Off Valve</b>
Model No. & Description: <i>(Refer <a href="http://www.aga.asn.au">www.aga.asn.au</a> for more details)</i>	<b>UNI-GERÄTE EPVO SERIES 10-4-EPVO 7-4R, 10-4-EPVO 10NH-4R, 10-4-EPVO 20NH-4R, 10-4-EPVO 25NH-4R</b>  <b>MWP 1000 kPa @ -20 to +60°C</b>
Relevant Standard(s):	<b>AS 4629-2005 (Inc Amendment 1 &amp; 2)</b>

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

**This Certificate is issued on the express conditions that:**

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



**Client Manager**

**Certificate Authorised**

Certificate first issued: **16 December 2002**

Certificate No: **6349**

This copy valid from: **21 December 2020**

Refer specification issue: **08**