

UKCA Type Examination Certificate

This is to certify that:

UNI-Geräte E. Mangelmann
Elektrotechnische Fabrik GmbH
Holtumsweg 13
Weeze
47652
Germany

Holds Certificate Number:

UKCA 772970

In respect of:

Automatic shut-off valves

Type samples representative of product(s) have been tested and examined according to the procedures specified in Annex III Module B (Type Examination) of The Product Safety and Metrology etc (Amendment etc)(EU Exit) Regulations 2020 (SI 2020/676) for the Regulation for Appliances burning gaseous fuels and found to comply with the Essential Requirements as detailed in Annex I of the Regulations.

For and on behalf of BSI, an Approved Body for the above Regulation (Approved Body Number 0086):

Shahm Barhom, Group Product Certification Director

First Issued: 2022-12-09

Latest Issue: 2022-12-09

Effective Date: 2022-12-09

Expiry Date: 2027-10-12



UKCA Type Examination Certificate

No. UKCA 772970

Type Test Report Number: TUV Report V577 2017 B3, V577 2017 T1 Rev 01
Project Number: BSI-Q558967

Model Designation	Gas Types	Normative Reference
VS... DVS...	1 st , 2 nd and 3 rd family gases	BS EN 16678:2015

Application Warning: These devices may not be suitable for all applications and it is the responsibility of appliance designers to select the control devices that are appropriate for their specific product design.

First Issued: 2022-12-09
Latest Issue: 2022-12-09

Effective Date: 2022-12-09
Expiry Date: 2027-10-12

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.